



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आज़ादी का  
अमृत महोत्सव

F.6/DFS/MS/Business/SZ/2022

/College/31

Dated: 08/07/2022

To

Mr. S. S. Akhtar, Registrar,  
Jamia Hamdarad (Deemed University),  
Hamdard Nagar, New Delhi-110062.

Ref: Letter JH/Civil Engg./Fire Safety/22/69 dated 20.06.2022.

Sub: Renewal of Fire safety Certificate to Academic Building located in Jamia Hamdard Campus, Hamdard Nagar, Tuglakabad Institutional Area, New Delhi-110062.

Sir,

This has reference to your letter regarding the subject mentioned above. In this context, it is informed that the building mentioned in the subject was visited by the officer concerned of this Dept. on 04.07.2022 in presence of Mr. M. Samshi (A.E. Civil) and it was observed that the building is comprised of basement, ground + 03 upper floors having height of 14.97 meters as per our records. The building is a business occupancy having offices from basement to 2<sup>nd</sup> floor and labs at 3<sup>rd</sup> floor.

Business buildings below the height of 15 meters or having less than Ground + 04 upper floors are not covered under Rule 27 of Delhi Fire Service Rules 2010 and hence the said building does not require clearance from Delhi Fire Service.

However, you are suggested to provide and maintain the Fire Safety provisions as per the requirements at the time of issuance of previous 'NOC', in the interest of public safety at large.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to:

1. The Commissioner, MCD, 9<sup>th</sup> floor, Dr. SPM Civic Centre, Minto Road, Delhi-110002.