

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Guest House/WZ/2022/ 589

Dated: 14/7/22

To,

Mr. Rohit Mishra,
House No.3329, 3rd floor,
Gali Hari Mandir Pahar Gang,
Swami Ran Tirth Nagar,
Delhi-110055.

Sub: Issue of FSC in r/o M/s Blue Saffron, Guest House in Plot No. 6, UF, FF, SF, TF, Pkt-27,
Sector-24, Rohini, Delhi-110085.

Sir,

Kindly reference to online application No.2022033104654 dated 09.06.2022 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **05.07.2022**, in presence of **Mr. Mohmd. Naem Akhter (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check doors are not provided.
2. Natural ventilation not provided in corridor & staircases.
3. Temporary shed provided in terrace.
4. CO2 detectors are not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250