

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

NO. F6/DFS/MS/EH/NDZ/2022/ 471

Dated:- 13.07.2022

To

The Manager,
M/S Cha-Bar (A Unit of Apeejay Oxford Book Stores (p) Ltd.)
N-81, F.F, Connaught Place, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Cha-Bar (A Unit of Apeejay Oxford Book Stores PVT Ltd) located at N-81, F.F, Connaught Place, New Delhi.

Sir,

This has reference to ID No. - 2022060812295 dated 08.06.2022 on the subject cited above. In this connection, it is to inform you that the site was inspected by the officers concerned of department on 05/07/2022 in the presence of Ms. Nitin (Manager) and observed that the shortcomings issued earlier vide letter No F6/DFS/MS/EH/NDZ/2021/496 dated 02.11.2021 (ID No. 2021092622599) (copy enclosed) are not complied so far. Hence, Fire Safety Certificate (FSC) cannot be issued at this stage.

Therefore, you are requested to rectify the shortcomings issued earlier vide aforesaid letter for further consideration in the matter

Yours faithfully

Encl : As above.

S. K. Dua
12/07/22

(S. K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic),
1st floor, Police Station,
Defence Colony, New Delhi.

m

C-17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/EH/NDZ/2021/496

Dated: 02.11.2021

To,

The Manager,
M/S Cha-Bar (A unit of Apeejay Oxford Book Stores (Pvt.) Ltd.)
N-81, F.F., Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Cha-Bar (A unit of Apeejay Oxford Book Stores (Pvt.) Ltd) located at N-81, F.F, Connaught Place, New Delhi. ID No. **2021092622599** dated 26.09.2021.

Sir,

This has a reference to online ID No **2021092622599** dated 26.09.2021 on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 12/10/2021 in the presence of Sh. Nitin Warikoo and the following shortcomings were observed:-

1. 02 Staircases of 1.5 meter each are not provided.
2. 02 Exits of 1.5 meter each are not provided.
3. First aid hose reel and hydrant systems are not provided.
4. MOEFA is not provided.
5. Terrace pump of 450 LPM is not provided.
6. Overhead fire water tank of 20,000liter capacity is not provided.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


(Arul Garg)
DIRECTOR
Delhi Fire Service


Copy to :-

The Addl. Commissioner of Police (Lic.),
Licensing Unit, Defence Colony Police Station, New Delhi