

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/ 412

Dated 14/7/22

To,

The Principal,
EDMC Pratibha Vidyalaya,
Jagjeevan Nagar, Kaithwada,
Delhi- 110053.

Sub:- Regarding Issuance Fire Safety Certificate r/o EDMC Pratibha Vidyalaya located at Jagjeevan Nagar, Kaithwada, Delhi- 110053.

Sir,

This is in reference to your letter No. EDMC/EE(E) -I/SHN/2021-22/D-40 dated 02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Sushil Kumar, In-charge of the School. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. First-Aid hose reels provided but not functional.
2. The discharge capacity & head of the fire pump could not be ascertained in absence of documents/technician.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

o/c
2.

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 18-24, FIE,
Patparganj, Delhi 92