

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/ 410

Dated 14/7/22

To,

The Principal,
EDMC Primary School
Brhampuri T Block, Gali No.12,
Gautampuri, Delhi- 110053.

Sub:- Regarding Issuance Fire Safety Certificate r/o EDMC Primary School located at Brhampuri T Block, Gali No.12, Gautampuri, Delhi- 110053.

Sir,

This is in reference to your letter No. EDMC/EE(E) -I/SHN/2021-22/D-40 dated 02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 07/06/2022 in presence of Mr. Vinod kumar, Principal of the School. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. The premises is not accessible of fire engines.
2. One staircase of width 1.36 meter is provided against requirement of two staircase of width 1.50 meter.
3. First-Aid hose reels provided but not functional.
4. The discharge capacity & head of the fire pump could not ascertained in absence of documents/technician.
5. Overhead water storage tank capacity 10,000 liters for firefighting not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

o/c

Copy to:-

The Director of Education, MCD
Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002