

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2022/611/581

Dated:-13/7/2022

To

The Manager
M/S Express 66, Guest House,
Plot no- 2, D.B.G. Road Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Express 66, Guest House located at Plot no-
2, D.B.G. Road, Pahar Ganj New Delhi.

Sir,

This has reference to Online id no.2022052411081 dated 25.05.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 30/06/2022 in the presence of **Manager** and following shortcomings were observed:-

1. CO detectors not provided as per gazette notification dated 27.05.2019.
2. Smoke management system not provided per gazette notification dated 27.05.2019.
3. Hose reel & pump found nonfunctional.
4. Fire extinguishers are due for refilling.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

S.K. Dua
13/07/22

(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.