



C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/ 2022/ 914

Dated: 14/7/2022

To,

The Principal,
Guru Harkishan Public School,
Road No.-73, Punjabi Bagh,
New Delhi -110026.

Sub: - **Inspection report in respect of Guru Harkrishan Public School Located at Road No. 73, Punjabi Bagh, New Delhi-110026.**

Sir,

With reference to your Email dated 18/05/2022 on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 26/06/2022 in the presence of Sh. Bhupinder Jeet Singh (principal) to see the functioning of the fire safety equipments provided in the building.


During inspection, it has been observed that the said school is running in total two blocks, Block-1 is (primary section) comprised of Basement + Ground + 02 Upper Floors (Basement is using as shooting academy), Ground floor is using for Auditorium & Administrative Offices, 1st floor is using for school purpose & 2nd floor is using by other management (College). Block 02 is (Sr. Sec block) comprised of Ground + 02 upper floors & both blocks are interconnected with each- other through corridor at 1st & 2nd floor, Was issued FSC vide letter No.F6/DFS/MS/School/WZ/2019/472 dated 07/03/2019. Fire safety arrangements such as, Fire Extinguishers, Hose reels, Terrace pump etc. are provided.

However, following shortcomings were observed: -

1. No any staircase is provided in Block-02 (Sr. Sec Block) against requirement of 02 X 1.5 mts.
2. First Aid Hose reels are provided but found leakage.
3. Terrace fire pump of 450 lpm & Jockey pump 180 lpm is provided but not on automode.
4. Exit signage's found removed.


In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Directorate of Education Old Secretariat Delhi - 110054.


07/7/2022