

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/011/578

Dated:-13.7.2022

To

The Manager
M/S Hotel Blessing Guest House,
5202,5206, Part 5198, Basant Road,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Hotel Blessing Guest House, 5202,5206, Part 5198, Basant Road, Pahar Ganj, New Delhi.


Sir,

This has reference to Online id no.2022052811483 dated 28.05.2022, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 04/07/2022 in the presence of **Sh. Deepak Kapoor** and following shortcomings were observed:-

1. Fire check doors are not provided as per gazette notification dated 27.05.2019.
2. Smoke management system not provided as per gazette notification dated 27.05.2019.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,


(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.