

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 403

Dated 14/7/22

To,

The Principal,  
Nav Jeevan Adarsh Sr. Sec School,  
Gautam Puri,  
Delhi-110053.

**Sub:- Regarding Issuance Fire Safety Certificate r/o Nav Jeevan Adarsh Sr. Sec School located at Gautam Puri, Delhi- 110053.**

Sir,

This is in reference to your letter No. NJAPS/2022/56 dated 02/06/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Parveen Baisala, Manager of the School. The following points / shortcomings were noticed in the building which is comprised of ground plus two upper floors.

1. Auto starting of terrace pump is not provided.
2. Overhead water storage tank capacity 4,000 liters is provided against requirement of 10,000 liters.
3. Exit signs are required to be provided in the school building at all exits.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

  
(S. K. Dua)  
Dy. Chief Officer /  
(NDZ)

Copy to:-

1. The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053