



No. F6 /DFS/MS/EH/SZ/2022 /467

Dated: 13/07/2022

To

The Joint Commissioner of Police,  
Office of Joint commissioner of Police: Licensing,  
1st Floor, P S Defence Colony, New Delhi.

Ref:- Online application no. 2022060311974 dated 03.06.2022.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Jubilant Foodworks Ltd (Dominos Pizza) situated at shop no 32-33, Ground floor, Grandlay Cinema Complex, New Delhi-110025.**

Sir,

With reference to the online application I.D. no. 2022060311974 dated 03.06.2022 on the subject cited above, it is informed that the said restaurant was inspected by Assistant Divisional Officer (M. Road) from this department on 17.06.2022 in the presence of Ms Annu (Manager) and it was observed that the restaurant is running at ground floor of the building which is comprised of basement + ground + 02 upper floors. During the inspection the following shortcomings were observed:

1. Alternate exit door width of 1.5 meter shall be provided instead of 0.95 m at rear end of the restaurant.
2. First aid hose reel found removed/not provided.
3. Down comer / yard hydrant systems found removed/not provided.
4. Electrical panels near the kitchen area shall be provided with local flooding system .

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

o/c [Signature]  
A717

**Copy to:-**

The Licensee, M/s Jubilant Foodworks Ltd (Dominos Pizza) situated at shop no 32-33, Ground floor, Grandlay Cinema Complex, New Delhi-110025.