



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/50  
आज़ादी का  
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2022/ 565

Dated 12/07/2022

To

The Joint Commissioner of Police: Licensing,  
1<sup>st</sup> Floor, P. S Defence Colony,  
New Delhi

**Sub:-** Regarding grant of Fire Safety Certificate in r/o **M/s Karon Hotel (Guest House) located at 61, Ring Road, Lajpat Nagar III, New Delhi.**

Sir,

With reference to online application no. 202251810627 dated 21.06.2022..on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (M. Road) from this department on 28.06.2022 in the presence of Sri Deepak Bakshi (Manager) and it was observed that the building is comprised of Basement + Ground + 03 upper floors. Following shortcomings were observed during the inspection:

1. Fire check doors have not been provided at all floors including basement.
2. Ventilation provisions are inadequate in the basement and upper floors.
3. Hose reel system found non functional.
4. CO detector system not provided.
5. Manually Operated Electrical Fire Alarm (MOEFA) found non functional.
6. Sprinkler system found removed in front portion of the basement.
7. Boosting arrangements found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Local Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

The Licensee,

M/s Karon Hotel (Guest House) located at 61, Ring Road, Lajpat Nagar III, New Delhi.

7/50  
DL  
DEPT