

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 408

Dated 14/7/22

To,

The Principal,
Nigam Pratibha Vidyalaya,
Khajuri Khas, Shahdara,
Delhi- 110094

Sub:- Regarding Issuance Fire Safety Certificate r/o Nigam Pratibha Vidyalaya located at Khajuri Khas, Shahdara, Delhi- 110094.

Sir,

This is in reference to your letter No. EDMC/EE(E) -I/SHN/2021-22/D-40 dated 02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Sh. Budhi Ram Rakesh, Principal of the School. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. The premises is not accessible to fire engines.
2. Two staircase of width 1.35 meter is provided against requirement of width 1.50 meter.
3. First-Aid hose reels provided but not functional.
4. The discharge capacity & head of the fire pump could not be ascertained in absence of documents/technician.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

ok p.

Copy to:-

1. The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002