

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 411

Dated 14/7/22

To,

The Principal,
Nigam Pratibha Vidyalaya
Gali No. 18, kailash Nagar, Akal Pali,
Delhi- 110031.

Sub:- Regarding Issuance Fire Safety Certificate r/o Nigam Pratibha Vidyalaya located at Gali No. 18, kailash Nagar, Akal Pali, Delhi- 110031.

Sir,

This is in reference to your Email ID. rajinderkumar2234@gmail.com dated 25/05/22 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Rajinder Kumar (Principal). The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. The Premises is not accessible to fire engines.
2. Staircase of width 1.50 meter shall be required to be provided.
3. First-Aid hose reels provided but not functional.
4. The discharge capacity & head of the fire pump could not be ascertained in absence of documents/technician.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002