

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/409

Dated 14/7/22

To,

The Principal,
Nigam Pratibha Co-ed Vidyalaya
Ajit Nagar, Delhi- 110031.

Sub:- Regarding Issuance Fire Safety Certificate r/o Nigam Pratibha Co-ed Vidyalaya located at Ajit Nagar, Delhi- 110031.

Sir,

This is in reference to your letter No. nil dated 24/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Rameshwar Dayal (Principal). The building comprised of ground plus three upper floors. Following shortcomings were observed during the time of inspection.

1. The Premises is not accessible to fire engines.
2. One staircase of width 1.30 meter is provided against requirement of two staircase of width 1.50 meter.
3. First-Aid hose reels provided but not functional.
4. The discharge capacity & head of the fire pump could not be ascertained in absence of documents/technician.
5. Exit signs are required to be provided in the school building at all exits.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Anil Garg)
Director

Delhi Fire Service

Copy to:-

1. The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002