



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/ 402

Dated 14/7/22

To,

The Principal,
MCD Primary School
South Gandhi Nagar,
Delhi-110031

Sub:- Regarding Issuance Fire Safety Certificate r/o Nigam Primary Vidyalaya located at Old Gandhi Nagar, near Gurudwara Gali, Delhi-110031.

Sir,

With reference to your letter no. nil dated 24/05/2022 on the subject cited above. In this connection this is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mrs. Sushma Goyal, Principal of the school on dated 22/06/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/School/2015/1526 dated 10/07/15 have not been complied yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully

(S. K. Dua)

Dy. Chief Fire Officer

Copy to:-

1. The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002

c/o

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. FC/DF/MS/school/2015/1526

Dated: 10/07/15

To,

The Principal (1st Shift)
EDMC Primary School,
Old Gandhi Nagar, Delhi-31

Sub: Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC
Primary School, Old Gandhi Nagar, Delhi-31.

Madam,

Please refer to your letter dated 27.05.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education. At the time of inspection Principal was present and it was observed that the school building is comprised of ground floor only and has following shortcomings.

1. The School is not accessible to fire engines as approach road width is less than 6 meters.

In view of above, the fire safety certificate cannot be considered at this stage.

Yours faithfully



(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025



Copy to-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (2nd Shift)
EDMC Primary School, Old Gandhi Nagar, Delhi-31