

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

482

No.F6/DFS/MS/GH/NDZ/579

Dated: 13/07/2022

To,

The Manager,  
M/S **Baba Residency**,  
7683/84 Plot No-42, Ram Nagar,  
Pahar Ganj, New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Baba Residency, 7683/84 Plot No-42, Ram Nagar, Pahar Ganj, New Delhi. (ID No. 2022052911588 dated 29.05.22).**

Sir,

This has reference to your online ID No. 2022052911588 dated 29.05.22, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 29.06.22 in presence of **Mr. Sachin** and following shortcomings were observed

1. Fire check doors & CO detectors are not installed as per gazette notification 27.05.2019.
2. Fire Pump not in auto mode provision.
3. Hose reel found nonfunctional.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

*S. K. Dua*  
12/07/22

(S. K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

*R*

**Copy to :-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.