



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 415

Dated: 14/7/22

To,

The Principal,
Prince Public School,
Sector-24, Rohini,
Delhi-85,

Sub: Issue of FSC in r/o Prince Public School, Sector-24, Rohini, Delhi-85.

Sir,

This is in reference to your letter No. PPS/22 dated 09.05.2022 received through outdoor diary no. 1242 dated 10.05.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **21.06.2022**, in presence of **Mr. Sandeep Gulati (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Sprinkler system provided but basement found extended without fire protection.
2. Physic lab found constructed around staircase effecting ventilation of staircase.
3. Temporary ply board rooms found to be constructed at various floors.
4. Facad found provided which is effecting the ventilation of exits in building passage.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

512
14/7