

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

CSJ 75  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/GH/NDZ/2022/ 586

Dated:-14/07/2022

To

The Manager,  
M/S The Metro Polis Guest House,  
15, Krishna Market, Pahar Ganj, New Delhi.

**Sub:** Regarding grant of FSC in r/o M/S The Metro Polis Guest House, 15, Krishna Market, Pahar Ganj, New Delhi. Id no. 2022053011654 dated 15.06.22.

Sir,

This has a reference to online ID No. id no. 2022053011654 dated 15.06.22 on the subject cited above, it is to inform you that the site was visited by the officer concerned of this department on dated 11.07.22 in presence of Mr. Hari (Manager) and following shortcomings were observed: -

- 1) Smoke management system and CO detectors at each floor are not provided as per gazette notification 27.05.2019.
- 2) Hose reel found non functional.
- 3) Terrace pump found non functional.
- 4) Terrace pump not provided with auto start provision.
- 5) No. of rooms as mentioned in application form are not matching with the rooms available in the guest house, and required to be clarified the same.
- 6) Building plans as uploaded are not legible.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings at the earliest for further consideration in the matter.

Yours faithfully



(S. K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police  
Station, New Delhi. : For necessary action please.