

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/EH/472

Dated:- 14.07.2022

To

The Manager,  
M/S Heisetasse Beverages Pvt Ltd,  
E-11, Mezzanine floor,  
Inner circle, Connaught place, New Delhi.

**Sub: Regarding issuance of FSC in r/o M /S Heisetasse Beverages Pvt Ltd., at E-11, Mezzanine floor Inner Circle, Connaught Place, New Delhi. ID NO. 2022052911606 dated 29.05.22.**

Sir,

This has reference to online ID No. **2022052911606 dated 29.05.22** on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 05/07/2022 in the presence of **Sh. Sachin** and following shortcomings were observed:-

1. 01 exit of 1.0 meter width is provided against the requirements of 2 exit of 1.5 meter each.
2. 01 Staircases of 1.20 to 1.0-meter width is provided against the requirements of 2 staircase of 1.5 meter each.
3. First aid hose reel and hydrant systems are not provided.
4. MOEFA is not provided.
5. Terrace pump of 450 LPM is not provided.
6. Overhead fire water tank of 20,000 liter capacity is not provided.
7. The complete set of building plan of the restaurant having all details such location of staircase, kitchen, exit, etc with duly signed by architect & owner /occupier is not uploaded.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.
2. DHO, NDMC, Palika Kendra, New Delhi – 110001.