

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/ *Audi/ 1744*

Dated:-*15.07*/...../2022

To

The Manager,
M/S Cafe Kendra Bhartiya Kala Kendra Trust,
No. 01, Copernicious Marg,
Mandi House, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Cafe Kendra Bhartiya Kala Kendra Trust at No. 01, Copernicious Marg, Mandi House, New Delhi. ID NO. 2021041012696 dated 24.05.22

Sir,

This has reference to online ID No. **2021041012696 dated 24.05.22** on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 06/07/2022 in the presence of **Sh. Umakant Sharma** and following shortcomings were observed:-

1. 02 exit of 1.0 meter each are provided against the requirements of 2 exit of 1.5 meter each.
2. First aid hose reel and hydrant systems are not provided.
3. MOEFA is not provided.
4. Terrace pump of 450 LPM is not provided.
5. Overhead fire water tank of 20,000 liter capacity is not provided.
6. The building plan of the premises is not signed by architect & owner /occupier.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.