

c15



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2022/School/398

Dated: 13/07/2022

To.

Smt. Mamta Yadav (Principal), <gcsv182181@gmail.com>
Govt. CO – ED Sarvodaya Vidyalaya,
Sector – 13, Dwarka,
New Delhi -110078

Subject: Renewal of Fire Safety Certificate in r/o Govt. CO – ED Sarvodaya Vidyalaya, Located at Sector – 13, Dwarka, New Delhi -110078 (School Id-182181).

Sir,

Please refer to your letter no GSC/S-13/DWK/187 Dated 02-06-2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 29/06/2022 in the presence of Sh. Amit Kumar (Estate Manager) for fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. Hose reel hose found non functional
2. Terrace pump found nonfunctional & not in auto mode.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi – 110054

129c
18/7/22