

027

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/School/2022/ 423
To

Dated/9/7/2022

The Manager
Great Mission Convent School
B-29, Kaushik Enclave, Burari, Delhi-84.

Sub: - Regarding issuance of fire safety certificate in r/o Great Mission Convent School located at B-29, Kaushik Enclave, Burari, Delhi-110084.


Sir,


This has reference to your letter received through online e-mail dated 30.06.2022. on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 07.07.2022 to verify the fire safety arrangements provided therein as per the Director of Education Circular dated 01.03.2011. At the time of inspection Smt. Poonam Rani (Principal) was also present at site and said building was comprised of ground & two upper floors only. The observations/ shortcomings noticed are as under:-

1. The approach road width is only 03m against the requirement of 06m for movement of fire engine in case of emergency.
2. Hose reel hose provided but found not functional and also some nozzle are missing.
3. MOEFA is not provided.
4. Terrace level fire pumps capacity 450lpm not provided.
5. Overhead fire water tank capacity 2,000ltr provided against the requirement of 10,000 ltr.
6. Exit signage's not provided at strategic location in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully


(Atul Garg)
Director

Ph:-011-23414000


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.