



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2022/417

Dated: 18/7/2022

To

The Principal,  
Iqra International School,  
H-69, Jaitpur Ext-II, New Delhi-44.

**Sub:-** Regarding renewal of Fire Safety Certificate in r/o **Iqra International School located at H-69, Jaitpur Ext-II, New Delhi-44.**

Sir,

With reference to your letter no. IIS/123/22 dated 17.05.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 16.06.2022 in the presence of Mr. Saeedur Rehman (Caretaker) and it was observed that the building is comprised of ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

o/c Rk  
12/7

**Copy to:-**

The Dy. Director of Education, GNCT of New Delhi, DISST. South Block-C, Defence Colony, New Delhi-24.