

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2022/SZ/ 1767

Dated 15/07/2022

To

The Authorized Signature,
MGF Metropolitan Mall,
Plot No A-2, & P2A,
District Centre, Saket, New Delhi-110017

Sub: - Regarding Renewal of fire safety certificate in r/o MGF Metropolitan Mall, Plot No A-2, & P2A, District Centre, Saket, New Delhi-110017

Sir,

This has reference with Gmail of Dated 19/05/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 07.07.2022 to ascertain the availability and operability of fire protection and fire safety measures as installed in the building. During the course of inspection, the following shortcomings/ observations were noticed:

- 1 The Fire Check Door found removed at one staircase at 1st Floor level.
- 2 The Ventilation/Pressurization system is not on auto mode.
- 3 There is a material Change in the building. You are requested either you may restore the earlier composition of building profile or otherwise submits application for sanction of building plans on common application form (CAF) with present floor wise occupancy, on the scales as mentioned in UBBL 2016.
- 4 The office Block building found under lock & key with occupier, hence, inspection of the office building could not be conducted.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR

Copy to:

1. The Joint commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi 49.
2. The Dy. Commissioner (South Zone) South Delhi Municipal Corporation, Green Park, New Delhi 110016.