1/20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/Banquet/WZ/2022/ 12 5

Dated: - 13/7/2022

To.

The Dy. Health Officer, Rohini Zone, Rohini Sector- 05, New Delhi.

Sub:- Renewal of Fire Safety Certificate in respect of M/s. Previous Forever Banquet Hall located at D-9, Udyog Nagar, New Delhi- 110041.

Sir.

This has reference to your online application received through MHA portal vide ID-2022042908865, on the subject cited above. In this connection, it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 02.07.2022 in presence of Sh. Suraj (Liaison Manager), to check the provisioning of fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said banquet hall is running at ground, first & second floor in a building comprised of basement, ground plus two upper floors. Fire safety arrangements such as fire extinguishers, hose reel, MOEFA, PA system, down comer, electric pump capacity 2280 lpm, diesel driven pump capacity 2280 lpm, jockey pump capacity 180 lpm, terrace pump capacity 450 lpm, overhead tank capacity 5000 lts. Underground water tank capacity 1,00,000 lts etc. found provided. However, following shortcomings have been observed:

- 1. Fire/smoke check doors found removed at some places.
- 2. Smoke management system found removed from basement & upper floors.
- 3. Automatic sprinkler system shall be extended in left out areas.
- 4. Hose boxes at all floors found removed.
- 5. Fire pumps are provided but not functional due empty underground water storage tank.
- 6. Underground water storage tank capacity 1,00,000 lts is provided but found empty.
- 7. Exit signages found removed.
- 8. Riser & Sprinkler system is provided but not functional.
- 9. Bridal rooms in basement floor & Kitchen running at terrace shall be removed.

In view of above shortcomings, the application for renewal of fire safety certificate is not consider at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Dharampal Bhardwaj)

Dy. Chief Fire Officer

West Zone,

Copy to:-

1. Sh. Sunil Juneja M/s. Previous Forever Banquet Hall, D-9, Udyog Nagar, New Delhi- 41.

6/6