



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 419

Dated 18/7/2022

To,

The Principal,
EDMC Primary School
Gautam Vihar, 4th Pusta, Delhi- 110053.

Sub:- Regarding Issuance Fire Safety Certificate r/o EDMC Primary School located at Gautam Vihar, 4th Pusta, Delhi- 110053.


Sir,

This is in reference to your letter No. nil dated 19/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Sanjeet. The building comprised of ground plus three upper floors. Following shortcomings were observed during the time of inspection.

1. First-Aid hose reels provided but not functional.
2. The discharge capacity & head of the fire pump could not be ascertained in absence of documents/technician.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully


(S. K. Dua) 18/07/22
Dy. Chief Fire Officer

o/c R

Copy to:-

The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002