

12/12/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2022

1791

Dated:

19/07/2022

To

Sr. Administrative Officer (Judicial),
Disaster Management Cell (Central),
Tis Hazari Courts, Delhi.

Ref:- Letter no. 14448-450/DMC/237/2022 dated 24.06.2022.

Sub:- Regarding carry out an inspection of Tis Hazari Courts Complex on 11.07.2022.

Sir,

This has reference to your letter no. 14448-450/DMC/237/2022 dated 24.06.2022 on the subject cited above. In this regard, it is submitted that Tis Hazari Courts Complex, Tis Hazari, Delhi was inspected earlier by a team of officers and given shortcomings vide letter no. F6/DFS/MS/2016/2698 dated 17.11.2016 & letter no. F6/DFS/MS/Business/NDZ/2021/1261 dated 29.06.2021 & F6/DFS/MS/NDZ/2022/1696 dated 08.07.2022 (copy enclosed) respectively. During inspection on dated 11.07.2022 at 11:00 hrs. Mr. Ishwar Singh (A.E. Civil) & Mr. Abhinav (J.E. Electrical) were present and following additional shortcomings were observed.

1. Detection system & fire alarm system of the building is not functional.
2. Judges lounge near staircase at 3rd floor is a temporary structure and causes hindrance in the exit route, i.e. exit staircase.
3. Hose reel hose at some places found not functional.
4. Most of the corridors are encroached with almirah's.
5. Delivery hoses not found in hose boxes.
6. Electrical cables found hanging at some places.
7. Electrical shafts not properly sealed.
8. Exit signages not provided in record room.
9. At some places hose reel hose not covering the Judges Chambers & offices.
10. Fire extinguishers are due for repairing & refilling at some places.
11. Additional public prosecutor corridor at 1st floor near room no. 167 found encroached with almirah's and offices.
12. Encroachment adjacent to main building may cause hindrance in fire fighting and rescue operation.
13. Diesel pump found non functional and main pump is not on auto mode.
14. The building is not accessible to fire engines due to heavy/ haphazard parking around the building and near the gates.

Annexe-I & Annexe-II building of Tis Hazari Court are less than 15 meter in height, does not fall under the purview of the building specified, under rule 27(8) of DFS Act 2007 & Rules 2010, hence FSC/clearance from this department is not required.

However, the fire safety arrangements are required to be installed and maintained in the building, as specified and recommended under the provision contained in National Building Code of India Part-IV/ UBBI.-2016, in the larger, interest of public safety.

You are requested to direct the concerned to rectify the shortcomings at the earliest.

Yours faithfully,



(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

- ✓ 1. The PS to Ld. Principal District & Sessions Judge (HQs), Tis Hazari Courts, Delhi.
2. The PS to Ld. Administrative Civil Judge (Central), Tis Hazari Courts, Delhi.
3. Executive Engineer (Electrical).