

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6 DFS MS School/WZ/2021/

956

Dated:

30/04/2021

To,

The Authorized Signatory,
Garg Trade Centre,
Community Center, Plot no.7,
Sector-11, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Community Center, Plot no.7, Sector-11, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 15.09.2021 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 04.03.2021 in presence of Sh. Satish Garg to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 6 meter road all around the building found obstructed on two sides due to temporary construction.
2. Exit discharged found closed in both stairs, only single exit through whole premises.
3. FCD & alternate exits of stairs found closed/ Blocked at second floor by fixing racks of departmental store in front of FCD and second exit was found through occupied area.
4. Lift lobby found removed in front of one lift car and FCD found removed at some places.
5. Lift lobby/ shaft pressurization found removed.
6. Sprinkler found removed at some places at first floor & non functional in basement.
7. MCP is found removed in basement.
8. Ventilation system found not functional in basement.
9. Terrace pump found not functional.
10. Additional two rooms found constructed on terrace which are not available on approved building plans
11. 5th floor was found under renovation & un-occupied.
12. Fire Control Room in Ground floor found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph: 011-23414000