



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/2022/SZ/ CGHS/1824

Dated: 2<sup>o</sup> /07/2022

To,

Sh. L.K Singhal (President)<someghs@yahoo.com>  
M/s Som CGHS Ltd,  
Plot no-24, Sector-6,  
Dwarka, New Delhi.

Subject: Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o M/s Som CGHS Ltd located at Plot no-24, Sector-6, Dwarka, New Delhi.

Sir,

Please refer to your Email Dated 27-06-2022 on the subject mentioned above. In this connection it is submitted that that the above said premises was visited by the officer concerned of this department on 11/07/2022 in the presence of Sh. L.K Singhal (President) to see the compliance of the shortcomings communicated vide this office letter no. F6/DFS/MS/SZ/2021/CGHS/2581 dated-10/12/2021 and found that the shortcomings are still not complied. You are requested to comply the shortcomings under intimation with this department.


In view of the above FSC from fire safety point of view cannot be considered at this stage.

Yours faithfully,

  
(Atul Garg)  
Director,

Delhi Fire Service.

Copy to:- 1. The Joint Director, DDA, Vikas Sadhan INA, New Delhi

  
18/7

C/75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/SZ/2021/ CGHS/2581

Dated: 10/12/2021

To.  
The Authorized Signatory,  
M/s Som CGHS Ltd,  
Plot no-24, Sector-6,  
Dwarka, New Delhi.

**Subject: Grant of Fire Safety Certificate in r/o M/s Som CGHS Ltd located at Plot no-24, Sector-6, Dwarka, New Delhi.**

Sir,

Please refer to your Email dated 01/11/2021 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 15/11/2021 for fire safety point of view.

**During the course of inspection following shortcomings have been observed**

1. The internal road found encroached/ blocked.
2. The stairs are found blocked & locked at terrace level.
3. Fire extinguishers of ABC type are found empty at some places.
4. Manual Operated Emergency Fire Alarm (MOEFA) is found nonfunctional.
5. Terrace Pump of 450 lpm with 40m head found nonfunctional in auto mode.
6. Exit signage found removed at some places.
7. Communication system alarm system & fireman ground switch are provided in the lift but found nonfunctional

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the above said shortcomings under intimation to this department for further necessary action.

Yours faithfully,

  
(Anil Garg)  
Director

Delhi Fire Service

Copy to:-

1. Joint Director, DDA, Vikas sadan, INA, New Delhi

  
11/12/21