



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2022/ 591

Dated: 18/7/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/S Batra Holiday Home located at 4, Bhogal Road, Jangpura (Near Rama Tent House), New Delhi-14.**

Sir,

With reference to Online application no. 2022061512891 dated 16.06.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (M. Road) from this department on 05.07.2022 in the presence Manager and it was observed that building is comprised of **Basement + Ground + 03 upper floors**. During inspection, following shortcomings were observed:-

1. Fire check door not provided in the guest house as per required in Gazette Notification dated 27.05.2019, Clause 7.31.X, UBBL 2016.
2. CO detectors with panel and alarm not provided in the guest house as per required in Gazette Notification dated 27.05.2019, Clause 7.31.VIII, UBBL 2016.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

o/c 11/7/22

**Copy to:-**

The Licensee, M/S Batra Holiday Home located at 4, Bhogal Road, Jangpura (Near Rama Tent House), New Delhi 14.