

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/WZ/2022/ 476

Dated: 18/07/2022

To

The Joint Commissioner of Police (Lic.),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub.-: Inspection report for issuance of Fire Safety Certificate in r/o M/s. Haldiram Product Pvt. Ltd. Located at shop No. SH/GF/24, Ground Floor, Pacific Mall, NSP, New Delhi.

Sir,

Please refer to the online application No. 2022052511165 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department, in presence of Sh. Sudhir Sharma (manager) on 27.06.2022 to check the status of the fire safety & means of escape measures provided in the building.

During inspection, it has been observed that the said restaurant is running at ground floor of Pacific Mall building comprised of 02 basements, lower ground, ground plus 04 upper floors. Fire fighting arrangements such as overhead tank capacity 20,000 lts, down comer, first aid hose reel, MOEFA, etc. found provided. However, the following shortcomings were observed:-

1. Two exits are located at side by side. It should be located remotely from one exit to another exit.
2. In built plan duly signed by registered architect and occupier of the restaurant with covered area is not uploaded on MHA portal.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite Fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(Anil Garg)
Director

Copy to: -

1. The Deputy Health Officer, North Delhi Municipal Corporation, Keshavpuram Zone, New Delhi.
2. Sh. Satish Kaushik, M/s. Haldiram Product Pvt. Ltd., Shop No. SH/GF/24, Ground Floor, Pacific Mall, NSP, New Delhi.