

1...m  
c/42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2022/477

Dated: 18/7/2022

To,

The Commissioner, Excise Department,  
GNCT of Delhi L Block, Vikas Bhawan,  
IP Estate, New Delhi 110002 (Email [dcexcise@nic.in](mailto:dcexcise@nic.in))

**Subject: Inspection report of M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.)  
Flat No.-22, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor, Khan Market, New Delhi**

Sir,

Please refer to your MHA portal ID-2022050909770 dated 10/05/2022 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officers concerned of this department on 09.07.2022 in the presence of Sh. Vipin Kumar and observed following shortcomings during the inspection:-

1. Only one staircase of width 1.00m is provided against requirement of 2 staircases of width 1.50mtr each.
2. MOEFA not provided.
3. Over Head Tank of 5,000 ltr is provided against requirement of 20,000 ltr capacity.

In view of above NOC/ FSC cannot be considered at this stage.

The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

Copy to:-

1. Addl. Commissioner of Police (Lic), 1<sup>st</sup> Floor, PS defence colony, New Delhi-110049.
2. M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.) Flat No.-22, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor, Khan Market, New Delhi