

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

C-61

No. F6/DFS/MS/GH/NDZ/2022/ 545

Dated: 08/7/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Arina Inn** located at **38, Netaji Subash Marg, Daryaganj, Delhi- 06.**

Sir,

This has reference to your online application I.D. no. 2022061112562 dated 11.06.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 29.06.2022 in the presence Mr. Mazhar Rabbani (Manager) and it was observed that building is comprised of Ground + 04 upper floors and the clearance is sought only for ground and three upper floors as per online application. During inspection, following shortcomings were observed:

1. Fire check door not provided required as per Gazette Notification dated 27.05.2019.
2. CO detectors with panel and alarm not provided required as per Gazette Notification dated 27.05.2019.
3. Public address system not provided.
4. Exit signages are not provided.
5. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Handwritten signature)
08/07

(S.K. Dua)

Dy. Chief Fire Officer o/l
Delhi Fire Service

8/7/22

Copy to:-

M/S Arina Inn at 38, Netaji Subash Marg, Daryaganj, Delhi- 06.