

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

No. F6/DFS/MS/BNQT/WZ/2022 11 2

To,

The Dy. Health Officer, D.M.C, Karol Bagh Zone, Anand Parbat, New Delhi (dhowest zone@gmail.com)

Subject:-Regarding issuance of NOC from fire safety point of view in respect of M/s Majestic Crown Banquet, Plot No.24, Najafgarh Road, Industrial Area, New Delhi-110015.

Sir,

Please refer to your online application no. 20222010900517 dated 10/05/2022 on the subject mentioned above. In this connection, it is to inform you that the premises was inspected by the officers of this department on 14/06/2022 in the presence of Sh. Sanjeev Oberoi (Owner) to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the building/premises comprised of Ground + 03 upper Floors was issued FSC vide letter no. F6/DFS/MS/2018/BNQT/2646 dated 10/12/2018 for ground & 1<sup>st</sup> floor only. Now applicant is applied for FSC Ground + 1<sup>st</sup> & 2<sup>nd</sup> floor. Fire Safety arrangements such as Fire Extinguishers, Smoke Management System, MOEFA, Internal Hydrant, First –Aid, Hose reel, Terrace pump, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

- 1. Smoke Management System is provided at upper floors but not functional.
- 2. Sprinkler System is found removed at upper floors.
- 3. Third floor found open & kitchen is also used on this floor. It should be sealed.

In view of above Shortcomings the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

Director

Delhi Fire Service

Copy To:-

- 1. The Executive Engineer (Building). North DMC, Karol Bagh Zone, Anand Parbat, New Delhi. (eepwddelhim132@gmail.com)
- 2. The Owner/ Occupier M/s. Sanjeev Oberoi, Majestic Crown Banquet, Plot No.24, Najafgarh Road, Industrial Area, New Delhi-110015.