

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/560

Dated:-11/7/2022

To

The Manager
M /S **Ricky Dx. Guest House**,
1242, Bazar Sangatrashan, Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S **Ricky Dx. Guest House**, 1242, Bazar Sangatrashan, Pahar Ganj, New Delhi.


Sir,

This has reference to online ID No. Online id no.2022042308071 dated 23.04.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 01/07/2022 in the presence of **Mr. Rajesh Kapoor** and following shortcomings were observed:-

1. Smoke management system are not provided as per gazette notification dated 27.05.2019.
2. CO Detector are not provided as per gazette notification dated 27.05.2019.
3. PA System found nonfunctional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi