

477

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/CM/576

Dated:-13/07/2022

To

The Manager  
M/S **Royal Plaza Guest House**,  
8167, Arakashan Road, Pahar Ganj,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S **Royal Plaza Guest House** located at 8167, Arakashan Road, Pahar Ganj, New Delhi.


Sir,

This has reference to Online id no.2022052411062 dated 24.05.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 06/07/2022 in the presence of **Manager** and following shortcomings were observed:-

1. Smoke management system not provided as per gazette notification dated 27.05.2019.
2. CO Detectors are not provided as per gazette notification dated 27.05.2019.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.