

C-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/SZ/ 458

Dated: 8/7/2022

To

The Dy. Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Starbucks Coffee A Tata alliance (unit of Tata Starbucks Pvt Ltd) shop No S 36A Ground Floor, Green Park Main Market, Delhi 110048.

Sir,

This has reference to your MHA Portal 2022020801845 dated 08/02/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.06.2022 in the presence of Mr. Kartik (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following points were observed:

1. There is one exit door having width of 1.50 mtr against the required two exits having width of 1.50 mtr each.
2. Hose reel hose not provided.
3. The MOEFA system is not provided.
4. The Internal Hydrant not provided.
5. Terrace level Fire Pump capacity of 450 LPM not provided.
6. Overhead tank capacity 20,000 ltrs not provided.
7. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.