

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2022/NDZ/ 479

Dated: 19/7/22

To,

Sh. Kulpreet Singh Kakkar
House No. 46, Jagan Nath Puri,
Delhi Road, Meerut,
Uttar Pradesh-250002

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Sukhleen Foods (Eating House) located G 8, Ground Floor, Cross River Mall, Vishwas Nagar Ext., Shahdara, Delhi 110032.

Sir,

With reference to your online MHA application No. 202206112602 dated 12/06/2022 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection the premises from fire safety point of view in presence of Mr. Ashish, Manager on dated 25/06/2022. The building comprise of basement, ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. Two Doors of width 2.10 mtr & 1.00 mtr are provided again requirement of 1.50 mtr. Each.
2. Exits signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

ok
2.

Copy to:-

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi