

CS

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 556

Dated:-11.1.22/2022

To,

The Manager,  
M/S Vintage Guest House,  
4897 Laddu Ghati , Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Vintage Guest House at 4897, Laddu Ghati , Pahar Ganj, New Delhi. ID No. 2022051610395 dated 23.05.22.**

Sir,

This has reference to on line ID No. 2022051610395 dated 23.05.22 on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 27.06.22 in presence of Mr. Jasbir Singh and found following shortcomings:-

1. The premises no. of guest house mentioned in online application form is 4897 whereas in building plan it is mentioned no. 4987.
2. 05 guest rooms are mentioned at third floor in the application form, whereas in building plan third floor is shown as closed and not in use.
3. Reception & waiting lounge is shown in the building plan, whereas use of stilt floor should be for parking. Same may be clarified.
4. Further, smoke management system is also not installed as per gazette notification 27.05.2019

In view of above shortcomings, the FSC cannot be issued at this stage .Therefore you are requested to clarify the same and furnish the correct information for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)

DIRECTOR  
Delhi Fire Service



**Copy to :-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.