

C-53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022/College/35

Dated: 25/07/2022

To,

The Director,
Rukmini Devi Institute of Advance Studies,
2A & 2B, Madhuban Chowk, Outer Ring Road, Phase-I,
Delhi-110085,

Sub: Issue of FSC in r/o Rukmini Devi Institute of Advance Studies, 2A & 2B, Madhuban Chowk, Outer Ring Road, Phase-I, Delhi-110085.


Sir,

This is in reference to your letter No. RDIAS/Misc./Fire Service/2022/330 dated 04.05.2022 received through outdoor diary no. 1214 dated 10.05.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **30.06.2022**, in presence of **Sh. Vikram Singh** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Basement hall found converted in rooms affecting fire safety & smoke ventilation.
2. Down-comer is found removed from basement.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

o/c
Dg