

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/

1877

Dated: 26.07.2022



To

Sh. Pramod Aggarwal,  
M/s IPEX Bhawan,  
Opp. Plato Public School, I.P Extn.,  
Delhi-11092.

**Subject:- Regarding grant of Fire Safety Certificate in r/o M/S IPEX Bhawan, Opp. Plato Public School, I.P Extn., Delhi-11092.**

Sir,

This has reference to your letter no. nil dated 20/05/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 04/07/2022 in the presence of Mr. Ram Kumar and observed that building comprised of Basement, Ground + 03 upper floors. During inspection following shortcomings were noticed:-

1. Fire check door found removed in basement.
2. Hose reel/Hydrants provided but found not functional.
3. Manual call point provided but found not functional.
4. Fire fighting pumps viz one electric, one diesel (stand by) having capacity of 1620 lit./min. & one Jockey Pump and one terrace pump having capacity 180 lit./min. & 900 lit./min. respectively not provided.
5. Underground water static tank of 50,000 liters capacity not provided.
6. Overhead water tank of 10,000 liters capacity not provided.
7. Exit signage and lift signage found removed.

In view of above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/ occupier. The Licensing Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)

Director

Delhi Fire Service

Copy to:-

The Commissioner,  
MCD, Civic Centre, J.L. Nehru Marg, New Delhi – 110002.