



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/WZ/2022/ 1875

Dated: - 21/07/2022

To,

Sh. Ashwani Kapoor,  
M/s. Kapo Footwears Pvt. Ltd.,  
Plot no. H-36, Udyog Nagar,  
Delhi-110041.

**Subject: Regarding renewal of Fire Safety Certificate in r/o M/s. Kapo Footwears Pvt. Ltd. Located at Plot no. H-36, Udyog Nagar, Delhi-110041.**


Sir,

This has reference to your Form "J" dated 19.05.2022 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 12.07.2022 in the presence of Sh. Tariq (Manager). During inspection, it has been observed that the said building is comprised of Basement + Ground + Mezz. floor + 1<sup>st</sup> floor only served with 02 staircases & 04 staircases (Basement). The Fire safety arrangement such as first aid hose reel, fire extinguisher, Smoke management, Automatic sprinkler system, fire pump, underground water tank & Overhead water tank etc found provided. However, the following points have been noticed as shortcomings:-

1. Fire check door found removed.
2. Staircase found not connected up to terrace floor shall be provided.
3. Exit signages found removed.

In view of the above shortcomings, renewal of FSC is not considered & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to :-

1. The Deputy Commissioner, MCD office, P-496-276, Rohini institutional area, Sector 5, Rohini. Delhi.