

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/2022/NDZ/ 425

Dated: 22 / 7 /2022

To

The Principal,  
Shishu Bharti Shiv Mandir Vidyalaya,  
Vishwakarma Nagar, Jhilmil, Delhi-110095.

**Sub:- Regarding Issuance Fire Safety Certificate in R/o Shishu Bharti Mandir Vidyalaya at Vishwakarma Nagar, Jhilmil, Delhi-110095.**


Sir,

With reference to your letter No. SBSM/064/2022 Dated 26/04/2022 on the subject cited above, in this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 25/05/2022 in presence of Sh. Vidhushi Sharma (Principal). The following points / shortcomings were noticed in the building comprised of ground plus two upper floors.

1. The staircase of 1.50 meters width not provided.
2. First-Aid hose reel (01 no.) in each floor is not provided.
3. A Fire pump having 450 LPM output at 40 meters head is not provided.
4. Over head tank 10,000 liters is not provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificated at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully,

  
( S.K.Dua )

Dy. Chief Fire Officer.

Copy to:-

The Director of Education (Land & Estate)  
Directorate of Education, Lucknow road,  
Delhi-110054.

