



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

4/58

1.

No. F6/DFS/MS/GH/NDZ/2022/ 620

Dated: 28/7/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Mumbai Palace Guest House** located at **774, Gali Imam Wali, Motor Market, Jama Masjid, Delhi-06.**

Sir,

This has reference to your online application I.D. no. 2022060311979 dated 03.06.2022 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 11.07.2022 in the presence Mr. Rahil (Manager) and it was observed that building is comprised of Ground + Mezzanine + 04 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm required as per Gazette Notification dated 27.05.2019, not provided.
2. Fire extinguishers found non functional.
3. Public address system not provided.
4. Exit signages are not provided.
5. Occupancy above 2nd floor is not permitted as per gazette notification dated 27.05.2019 and shall not be used for any purpose.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Signature)
27/7/22

(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

M/S Mumbai Palace Guest House, located at 774, Gali Imam Wali, Motor Market, Jama Masjid, Delhi-06.

ok
27/7