



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

c/b

No.F6/DFS/MS/School/SZ/2022/ 437

Dated: 28/7/2022

To

The Principal,
The Indopride Literacy Mission,
1st 8/498, Near Bandh Road, Budh Bazar,
Sangam Vihar, New Delhi-80.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **The Indopride Literacy Mission [Managed by The Indopride Foundation, (Regd.)] located at 1st 8/498, Near Bandh Road, Budh Bazar, Sangam Vihar, New Delhi-80.**

Sir,

With reference to your letter no. TILM/01/2022-2023 dated 20.05.2022 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 20.07.2022 in the presence of In-charge and it was observed that the school building is comprised of Ground + 03 upper floors (3rd floor semi pacca for 2 rooms). During the inspection following shortcomings were observed:-

1. Alternate staircase of 1.50 meters width shall be provided in the building.
2. First-aid-hose reels not provided.
3. Fire pump having capacity 450 LPM & head 40 mtrs. not provided.
4. Overhead water tank 10,000 ltrs for firefighting not provided.
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

g/c 27/7/22

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.