

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/WZ/2022/ 499

Dated: 28/7/2022

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Sub.: Inspection report for issuance of Fire Safety Certificate in r/o M/s. Café Rocking Evils (a unit of Café Moonstars Pvt. Ltd.), Shop No. 202, 2<sup>nd</sup> Floor, PP Tower, Netaji Subhsh Place, New Delhi- 110034.

Sir,

Please refer to the online application No. 2022061612900 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department, in presence of Sh. Akash Sharma (owner) on 18.07.2022 to check the status of the shortcomings pointed out by this department vide letter No. F6/DFS/MS/EH/2022/WZ/05 dated 05.01.2022 (copy enclosed), but no improvement was observed during the course of inspection.

In view of the above, the application for grant of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite Fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Copy to: -

1. The Deputy Health Officer, Delhi Municipal Corporation, Keshavpuram Zone, New Delhi.
2. Sh. Akash Sharma, M/s. Café Rocking Evils (a unit of Café Moonstars Pvt. Ltd.), Shop No. 202, 2<sup>nd</sup> Floor, PP Tower, Netaji Subhsh Place, New Delhi- 110034.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/EH/2021/WZ/05

Dated: 05/01/2022

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit,  
Police Station, Defence Colony,  
New Delhi.

**Subject: - Issuance of Fire Safety Certificate in r/o M/s. Café Rocking Evils (A Unit of Café Moonstar Pvt. Ltd.), Located at Unit no. 202, Second floor, P.P. Tower, Netaji Subhash Place, Delhi-110034.**

Sir,

Please refer to online application no. 2020022803157 dated 03.11.2021 on the subject cited above. In this connection it is to inform you that the aforesaid restaurant building has been inspected by the officer concerned of this department on 14.12.2021 in the presence of Sh. Tarsem Kumar (Partner), to check Fire Safety System & means of escape provided in the building.

**During inspection, the following shortcomings have been observed:-**

1. Alternate Staircase having width 1.5 m is not provided.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Copy to:-

1. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.
2. Sh. Akash Sharma, M/s. Café Rocking Evils (A Unit of Café Moonstar Pvt. Ltd.), Located at Unit no. 202, Second floor, P.P. Tower, Netaji Subhash Place, Delhi-110034.