

C/118

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 440

Dated: 28/7/2022

To,

The Principal,
St. Marks Sr. Sec. School, C-1/12,
Janakpuri, New Delhi,

Sub: - Regarding issuance of Fire Safety Certificate in r/o. St. Marks Sr. Sec. School, C-1/12,
Janakpuri, New Delhi

Sir,

This has reference to your Letter No. Nil dated 13/06/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 11/07/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mr. Ram Avtar Aggarwal was present and it was observed that the school building is comprised of Basement, stilt, ground plus two upper floors and have following shortcomings.

1. First aid hose reels provided but not functional.
2. Fire pump having 450 lpm provided but not functional at terrace.
3. Exits signage's are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)

Director

Delhi Fire Service

2022

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.