

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2022/SZ/ 1998

Dated: 29/07/2022

To  
The Executive Engineer (Bldg),  
SDMC, Jal Vihar Lajpat Nagar,  
New Delhi 110024

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Delhi Association of the Deaf at C-12, Qutab Institutional Area, New Delhi-110016

Sir,

This has reference with letter no nil dated 21/03/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 15.07.2022 in the presence of Sh. Dinesh (care taker) and observed that the building is comprised of Basement, Ground + Two upper floor. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door not provided.
2. Pump not on auto mode.
3. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

Copy to:-

1. Delhi Association of the Deaf at C-12, Qutab Institutional Area, New Delhi-110016