



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/WZ/2022/ 1921

Dated: - 29/07/2022

To,

Sh. Surinder Kumar Taneja,  
M/s. Krishna International LLP,  
Plot no. E-5, Udyog Nagar,  
Rohtak Road, Delhi-110041.

**Subject: Regarding renewal of Fire Safety Certificate in r/o M/s. Krishna International LLP  
Located at Plot no. E-5, Udyog Nagar, Rohtak Road, Delhi-110041.**


Sir,

This has reference to your Form "I" dated 18.05.2022 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 16.07.2022 in the presence of Sh. Akhilesh Kumar (Account Manager). During inspection, it has been observed that the said building is comprised of Basement + Ground + Mezz. floor + 1<sup>st</sup> floor only served with 01 staircases & 01 staircase (Basement). The Fire safety arrangement such as fire extinguisher, fire pump, overhead water tank & underground water tank etc found provided. However, the following shortcomings have been observed:-

1. The width of Main Exit is 3.40 m instead required 05 m clear.
2. Fire Check Door found removed at Basement.
3. Staircase found not connected up to terrace floor shall be provided.
4. First aid hose reel found nonfunctional.
5. Overhead water tank could not identify as down-comer is not connected to tank shall be provided 25,000 ltrs capacity.
6. In Basement, automatic sprinkler system is provided but found not connected to overhead water tank.
7. Exit signages found removed.

In view of the above shortcomings, renewal of FSC is not considered & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)