



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/WZ/2022/ 1920

Dated: - 29/07/2022

To,

Sh. Shikhir Chawla,
M/s. Prem Plastic,
Plot no. K-88, Udyog Nagar,
Rohtak Road, Delhi-110041.

Subject: Regarding renewal of Fire Safety Certificate in r/o M/s. Prem Plastic Located at Plot no. K-88, Udyog Nagar, Rohtak Road, Delhi-110041.

Sir,

This has reference to your Form "1" dated 25.05.2022 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 16.07.2022 in the presence of Sh. Prem Bahdur Ramoli (Helper). During inspection, it has been observed that the said building is comprised of Basement + Ground + Mezz. floor + 1st floor only served with 01 staircases & 02 staircase (Basement). The Fire safety arrangement such as fire extinguisher, fire pump, overhead water tank & underground water tank etc found provided. However, the following shortcomings have been observed:-

1. Fire Check Door found removed at Basement.
2. Smoke Management system found removed at basement.
3. First aid hose reel found removed.
4. Automatic sprinkler system found removed at basement.
5. Internal hydrant found removed.
6. Terrace pump 900 lpm capacity found removed.
7. Underground water storage tank 50,000 ltrs capacity & Overhead water storage tank 2,000 ltrs capacity for firefighting exclusive found removed.
8. Exit signages found removed.
9. Two rooms constructed at terrace floor shall be removed.

In view of the above shortcomings, renewal of FSC is not considered & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)